Certificate of Compliance

No. 2P190926.HFPCT52



Certificate's Holder:

HD Fire Protect Pvt. Ltd.

Registered Office Address & Factory Address:

K98, K97/1 and K97/2, Ajanta Road, MIDC, Jalgaon –

425 003, Maharashtra, India.

Certification FCM Mark:



Product: Model(s):

Bladder Tank Proportioning System

1. Bladder Tank Proportioning System – Vertical Tank Concentrate Storage Capacity: 800 litres to 7500 litres

2. Bladder Tank Proportioning System – Horizontal Tank Concentrate Storage Capacity: 800 litres to 15000 litres

Verification to:

Standard:

Compliance with the Materials Specifications of the Directive by Particular Material Appraisals as Referred to in the Third Indent of 4.2 (B) of Annex I Essential Safety Requirements

related to CE Directive(s): 2014/68/EU (Pressure Equipment)

Remark: The product(s) has been verified on a voluntary basis. The product(s) satisfies the requirements of the Certification Mark of ECM, in reference to the above listed Standard(s). The above Compliance Mark can be affixed on the product(s) accordingly to the ECM regulation about its release and its use. The regulation can be found at www.entecerma.it. This Certificate of Compliance can be checked for validity at www.entecerma.it

This verification doesn't imply assessment of the production of the product(s).

Additional information, clarification about the CE Marking:



We attest that a TCF for the CE Marking process is in place. Whereas the Manufacturer is Responsible to start the CE Marking Certification Procedure through an appointed Notified Body and the perform all the necessary activities, as required by the Directive and accepted by the Notified Body, before placing the CE Mark on the product(s).

Date of issue 26 September 2019

Expiry date 25 September 2024



