

CERTIFICATE OF COMPLIANCE

Certificate Number 20170102-EX15835
Report Reference EX15835-20130329
Issue Date 2017-JANUARY-02

Issued to: HD FIRE PROTECT PVT LTD
K-98, MIDC
AJANTA RD
JALGAON MH 425003 INDIA

This is to certify that representative samples of PROPORTIONERS, FOAM CONCENTRATE
"See Addendum Page"

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 162 - UL Standard For Safety For Foam Equipment and Liquid Concentrates

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20170102-EX15835
Report Reference EX15835-20130329
Issue Date 2017-JANUARY-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

36 to 3963 gal capacity ASME for horizontal installation. 36 to 1982 gal capacity ASME for vertical installation. Models RCF-B,-S and RCW-B,-S ratio flow controllers in sizes 2-1/2, 3, 4, 6 and 8 In.

Following are the equivalent length values for the controllers based on a roughness factor of 130 and Schedule 40 steel pipe:

Controller Size In.	Equivalent Length Ft
2-1/2	38.2
3	21.8
4	16.7
6	30.1
8	55.3

Models RCW-BM, -SM, and RCF-BM,-SM ratio flow controllers in the 2-1/2 In. and 6 In. size.

Following are the equivalent length values for the controllers based on a roughness factor of 130 and Schedule 40 steel pipe:

Controller Size In.	Equivalent Length Ft
2-1/2	357.2
6	48.9



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

