

CERTIFICATE OF COMPLIANCE

Certificate Number 20181011-EX15835
Report Reference EX15835-20180731
Issue Date 2018-OCTOBER-11

Issued to: HD FIRE PROTECT PVT LTD
K-98, MIDC
AJANTA RD
JALGAON Maharashtra 425003 INDIA

**This is to certify that
representative samples of**

PROPORTIONERS, FOAM CONCENTRATE
Models PS and PB proportioner modules incorporating size
2-1/2, 3, 4, 6 or 8 in. HD FIRE ratio flow controller and 1-
1/2, 2 in. balancing valve, with or without manual override.

Model PMS and PMB proportioner module incorporating
size 2-1/2 in. HD FIRE ratio flow controller and 1-1/2 in.
balancing valve, with or without manual override.

Refer to the individual foam concentrate Listings for
operating limitations with specific combinations of foam
concentrates and proportioners


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 162, Standard for Safety for Foam Equipment and
Liquid Concentrates

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

