



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
HD401	5.6	Pendent	SR	Job G5 5mm	1/2	Brass, Chrome	135, 155, 200 (57, 68, 93)
HD501	5.6	Pendent	QR	Job F3 3mm	1/2	Brass, Chrome	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for:

HD Fire Protect Pvt. Ltd.
D-6/2, Road No. 34, Wagle Industrial Estate
Thane, 400604 Maharashtra, India

FM Approvals Class: 2017

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR458928

Approval Granted: December 28, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

January 11, 2021

Date



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
HD101	5.6	Pendent	SR	Norbulb N5 5mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200 (57, 68, 79, 93)
HD101	5.6	Recessed Pendent	SR	Norbulb N5 5mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200 (57, 68, 79, 93)
HD102	5.6	Upright	SR	Norbulb N5 5mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200 (57, 68, 79, 93)
HD104	5.6	Concealed Pendent	SR	Norbulb N5 5mm	1/2	Brass	155, 175, 200 (68, 79, 93)

Prepared for:

HD Fire Protect Pvt. Ltd., C-3/6, Nandanvan Industrial Estate, LBS
Marg, Thane (W) – 400604, Maharashtra, India

FM Approvals Class: 2016, 2017, 2015

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055423

Approval Granted: April 10, 2015

To verify the availability of the Approved product, please refer to www.approvalguide.com

Supersedes certificate dated April 10, 2015

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

May 29, 2015

Richard B. Dunne
Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

Date



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
HD201	5.6	Pendent	QR	Norbulb N3 3mm	1/2	Brass, Chrome, Polyester	155, 175, 200 (68, 79, 93)
HD201	5.6	Recessed Pendent	QR	Norbulb N3 3mm	1/2	Brass, Chrome, Polyester	155, 175, 200 (68, 79, 93)
HD202	5.6	Upright	QR	Norbulb N3 3mm	1/2	Brass, Chrome, Polyester	155, 175, 200 (68, 79, 93)
HD204	5.6	Concealed Pendent	SR	Norbulb N3 3mm	1/2	Brass	155, 175, 200 (68, 79, 93)

Prepared for: HD Fire Protect Pvt. Ltd., C-3/6, Nandanvan Industrial Estate, LBS
Marg, Thane (W) – 400604, Maharashtra, India

FM Approvals Class: 2016, 2017, 2015
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055423

Approval Granted: April 10, 2015

To verify the availability of the Approved product, please refer to www.approvalguide.com

Supersedes certificate dated April 10, 2015

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read "Richard B. Dunne".

Richard B. Dunne
Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

May 29, 2015

Date