



# Certificate of Compliance

This certificate is issued for the following equipment:

## Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
HD402	5.6	Upright	SR	Job G5 5mm	1/2	Brass, Chrome	135, 155, 200 (57, 68, 93)
HD502	5.6	Upright	QR	Job F3 3mm	1/2	Brass, Chrome	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for:

HD Fire Protect Pvt. Ltd.  
D-6/2, Road No. 34, Wagle Industrial Estate  
Thane, 400604, Maharashtra, India

FM Approvals Class: 2016

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR458928

Approval Granted: December 28, 2020

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA

January 11, 2021

Date



Member of the FM Global Group



# Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
HD101	5.6	Pendent	SR	Norbulb N5 5mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200 (57, 68, 79, 93)
HD101	5.6	Recessed Pendent	SR	Norbulb N5 5mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200 (57, 68, 79, 93)
HD102	5.6	Upright	SR	Norbulb N5 5mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200 (57, 68, 79, 93)
HD104	5.6	Concealed Pendent	SR	Norbulb N5 5mm	1/2	Brass	155, 175, 200 (68, 79, 93)

Prepared for: HD Fire Protect Pvt. Ltd., C-3/6, Nandanvan Industrial Estate, LBS  
Marg, Thane (W) – 400604, Maharashtra, India

FM Approvals Class: 2016, 2017, 2015  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055423

Approval Granted: April 10, 2015

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

*Supersedes certificate dated April 10, 2015*

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

May 29, 2015

Richard B. Dunne  
Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA

Date



*Member of the FM Global Group*



# Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
HD201	5.6	Pendent	QR	Norbulb N3 3mm	1/2	Brass, Chrome, Polyester	155, 175, 200 (68, 79, 93)
HD201	5.6	Recessed Pendent	QR	Norbulb N3 3mm	1/2	Brass, Chrome, Polyester	155, 175, 200 (68, 79, 93)
HD202	5.6	Upright	QR	Norbulb N3 3mm	1/2	Brass, Chrome, Polyester	155, 175, 200 (68, 79, 93)
HD204	5.6	Concealed Pendent	SR	Norbulb N3 3mm	1/2	Brass	155, 175, 200 (68, 79, 93)

Prepared for:

HD Fire Protect Pvt. Ltd., C-3/6, Nandanvan Industrial Estate, LBS  
Marg, Thane (W) – 400604, Maharashtra, India

FM Approvals Class: 2016, 2017, 2015

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055423

Approval Granted: April 10, 2015

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

*Supersedes certificate dated April 10, 2015*

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark red ink, appearing to read "Richard B. Dunne".

Richard B. Dunne  
Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA

May 29, 2015

Date



# Certificate of Compliance

This certificate is issued for the following equipment:

## Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
HD401	5.6	Pendent	SR	Job G5 5mm	1/2	Brass, Chrome	175 (79)
HD402	5.6	Upright	SR	Job G5 5mm	1/2	Brass, Chrome	175 (79)
HD403	5.6	Horizontal Sidewall	SR	Job G5 5mm	1/2	Brass, Chrome	175 (79)

Prepared for:

HD Fire Protect Pvt. Ltd.  
D-6/2, Road No. 34, Wagle Industrial Estate, Thane, 400604  
Maharashtra, India

FM Approvals Class: 2012, 2016, 2017

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR462170

Approval Granted: February 24, 2022

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA

