

Certificate of Compliance

Certificate Number:

UL-US-2312517-2

Report Reference:

EX15835-20130329

Issue Date:

2024-05-16

Issued to:

**HD FIRE PROTECT PVT LTD
K-98, MIDC
AJANTA RD JALGAON, Maharashtra 425003
India**

This certificate confirms that representative samples of:
GHXV - Proportioners, Foam Concentrate

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 162, Edition 8, Issue Date 2018-02-23, Revision Date 2022-06-10

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2312517-2
Report reference EX15835-20130329
Date 2024-05-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
36 to 1982 gal capacity ASME for vertical installation with Models RCF-B,-S,-N and RCW-B,-S,-N ratio flow controllers	RATIO-FLOW CONTROLLER WITH BLADDER TANK
36 to 1982 gal capacity ASME for vertical installation with Models RCW-BM, -SM, -NM and RCF-BM,-SM, -NM ratio flow controllers	RATIO-FLOW CONTROLLER WITH BLADDER TANK
53 to 5285 gal capacity ASME for horizontal installation with Models RCW-BM, -SM,-NM and RCF-BM,-SM, -NM ratio flow controllers	RATIO-FLOW CONTROLLER WITH BLADDER TANK
53 to 5285 gal capacity ASME for horizontal installation with Models RCF-B,-S,-N and RCW-B,-S, -N ratio flow controllers	RATIO-FLOW CONTROLLER WITH BLADDER TANK
PMN	RATIO-FLOW CONTROLLER WITH BALANCED PRESSURE VALVE
PN	RATIO-FLOW CONTROLLER WITH BALANCED PRESSURE VALVE



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

